

## NBS Style Specification

M50

Rubber/plastics/cork/lino/carpet tiling/sheeting

### 161 WALL CLADDING – PVC SHEET

- Location:
- Base:
- Moisture content: All substrates to be dry to 16% WME (wood moisture equivalent) on Protimeter Surveymaster equipment.
- Cladding:
- Manufacturer: Interclad Ltd 173 Main Road Biggin Hill Kent TN16 3JR  
[www.interclad.co.uk](http://www.interclad.co.uk) sales@interclad.co.uk
- Product reference: Mediclاد hygienic PVC wall cladding, extruded
- Length: 2500mm or 3000mm
- Width: 1220
- Thickness: 2.5mm
- Colour: Matt White

Method of fixing: Sheets to be fixed using one of the following methods:

- Interclad 007 Adhesive
- Interclad Superbond Adhesive
- Installation temperature: Minimum ambient temperature of 14°C required in all installation areas
- Joint treatment: All joints between PVC panels to be covered with PVC 'H' joint section
- Corner details and abutments: Thermoformed or Interclad PVC extrusions
- Accessories: As necessary to complete system as Interclad requirements
- Finishing: Protective film to be removed; wipe off any marks and dirt using Interclad cleaner/thinner. Silicone seal to abutments.
- Treatment to service penetrations: All holes to be cut to allow 3-4mm

silicone seal around all penetrations. Clean with cleaner and seal with silicone sealant.